

TEST CERTIFICATE (P)

Concerning the examination of "Compound MEC-SINT/VULKANITE" in accordance with the KTW-guideline of Umweltbundesamt (UBA)

Manufacturer: PIDIGI S.p.A., VERONA, Italien
 Type of the test material: flat gasket material
 Brand Name of the test material: "Compound MEC-SINT/VULKANITE"
 Type of the sample: sheets
 Samples received: 20.04.2012
 Sampler: manufacturer
 TZW-reference-no.: KA 0247/17

Test results

1. Material composition: was given under KC 408/17 and approved
2. Migration test:

Cold water 23°C	1. – 3. day	4. – 6. day	7. – 9. day	Standard value for 3. extr.
Clarity, colour, taste, odour, foaming	TON 4 rubber, muffled	TON 2 rubber	nsa	not significantly affected
C-migration [mg C/m²d]	48	39	25	≤ 125

DC

The examined samples "Compound MEC-SINT/VULKANITE" comply with the requirements of KTW- guideline of Umweltbundesamt (UBA) (Bundesgesundheitsblatt 2005) in the range of gaskets.


Remarks:

This certificate is referring to the first evaluation (TZW-Az.: KA 126/12) dated on 29.05.2012 and was transcribed to English under (TZW-Az.: KA 176/12) dated on 18.06.2012.

This certificate expires on 28.05.2022, if not otherwise limited by product standards/certification reasons or by changes in the procedural conditions.

Reference to the original German text is recommended if necessary.

Karlsruhe, 18.07.2017


 Dr. J. Klinger / i.V. Dr.-Ing. R. Turković
 Head of the Test Centre

The publication of this test certificate - completely or in parts - is not permitted except of written approval by the test centre