

Approval Number: 1605506
Test Report: MA5621/G



23rd May 2016

Pidigi Spa
Via Della Meccanica 29,
Zai 2 Basson,
37139 Verona,
Italy

Water Regulations Advisory Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

WATER REGULATIONS ADVISORY SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

FIBRE

5075

'Mec-Sint/Vulkanite Bio'. Red coloured, compressed fibre gasket material. For use with water up to 65°C. For use only as a jointing/gasket material having been tested at a reduced surface area to volume ratio.

APPROVAL NUMBER: 1605506
APPROVAL HOLDER: PIDIGI SPA

The Scheme reserves the right to review approval.
Approval 1605506 is valid between May 2016 and May 2021

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect: on water quality".

The Directory may be found at: www.wras.co.uk/directory

Yours faithfully

A handwritten signature in black ink, appearing to read 'Jason Furnival'. The signature is written in a cursive, flowing style.

Jason Furnival
Approvals & Enquiries Manager
Water Regulations Advisory Scheme